



Thursday ,16th July 2020

Mr Jake Alleston

Encapsulation Solutions Ltd
Unit 3 Ripley Close,
Normanton,
Wakefield,
WF6 1TB

Dear Jake

RE: ECOSEAL ENCAPSULANT PRODUCT TESTS

SGS UK Ltd confirms that the testing carried out by our colleagues in the Netherlands LW-NBO-19040801 meets or exceeds the sensitivity requirements of a standard UK airborne fibre analysis to HSG248 and demonstrated in the scenario concerned that there was no measurable fibre release at or above the typical UK limit of detection of <0.01f/ml. The test carried out by SGS Search BV is accredited by the Netherlands' accrediting body, their equivalent of UKAS, to the same ISO17025 standard as assessed by the international accrediting body ILAC, to which UKAS also conform. The test results can therefore, in our view, be deemed at least equivalent to the UK standard and in the scenario tested, demonstrated that there was no detectable fibre concentration released from the surface treated with the Ecoséal product.

Best Regards

Paul King,

SGS UK Technical Manager

Alasdair Nairn

SGS UK Operations Manager